



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/03/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.260	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.164	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.069	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.107	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.097	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.065	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/04/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/04/2024	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.017	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/05/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/05/2024	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/06/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.024
	07:00 AM	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.023
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/06/2024	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/07/2024	06:00 AM	0.000	0.000	0.000	0.000	0.108	0.052	0.000	0.000	0.078
	07:00 AM	0.000	0.000	0.000	0.000	0.293	0.060	0.000	0.000	0.088
	08:00 AM	0.000	0.000	0.000	0.000	0.568	0.043	0.000	0.000	0.087
	09:00 AM	0.000	0.000	0.000	0.055	0.025	0.000	0.000	0.000	0.077

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/07/2024	10:00 AM	0.000	0.000	0.000	0.124	0.000	0.000	0.000	0.000	0.090
	11:00 AM	0.000	0.000	0.000	0.071	0.000	0.000	0.000	0.000	0.068
	12:00 PM	0.000	0.000	0.000	0.018	0.000	0.000	0.000	0.000	0.047
	01:00 PM	0.000	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.027
	02:00 PM	0.000	0.000	0.000	0.038	0.000	0.000	0.000	0.000	0.011
	03:00 PM	0.000	0.000	0.000	0.089	0.000	0.000	0.000	0.000	0.002
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/10/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.005
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.006
	08:00 AM	0.000	0.000	0.000	0.075	0.000	0.000	0.000	0.000	0.015
	09:00 AM	0.000	0.000	0.000	0.088	0.000	0.000	0.000	0.000	0.020
	10:00 AM	0.000	0.000	0.000	0.068	0.000	0.000	0.000	0.000	0.014

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/10/2024	11:00 AM	0.000	0.000	0.000	0.029	0.000	0.000	0.000	0.000	0.002
	12:00 PM	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.020	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/11/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.001
	10:00 AM	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.007
	11:00 AM	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.002

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/11/2024	12:00 PM	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/12/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.004	0.000	0.001
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.016
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.017
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.000	0.015

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/12/2024	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.010
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.022
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.020
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.010
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.005
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.006
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.006
06/13/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/13/2024	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/14/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/14/2024	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/17/2024	06:00 AM	0.000	0.592	0.000	0.000	0.000	0.000	0.000	0.000	0.069
	07:00 AM	0.000	0.465	0.000	0.000	0.000	0.000	0.000	0.000	0.066
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.057
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.030
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/17/2024	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/18/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/18/2024	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/20/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000	0.024
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.019	0.000	0.000	0.025
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.015	0.000	0.000	0.024
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.013
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/20/2024	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/21/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/21/2024	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/24/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.077
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.058
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.048
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.040
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.040
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.010
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/24/2024	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06/25/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/26/2024	06:00 AM	0.000	0.000	0.000	0.000	0.194	0.000	0.000	0.000	0.226
	07:00 AM	0.000	0.003	0.000	0.000	0.187	0.000	0.000	0.000	0.239
	08:00 AM	0.000	0.030	0.000	0.000	0.180	0.000	0.000	0.000	0.186
	09:00 AM	0.000	0.002	0.000	0.000	0.077	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/27/2024	06:00 AM	0.000	0.228	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/27/2024	07:00 AM	0.000	0.771	0.000	0.000	0.000	0.000	0.000	0.000	0.094
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.152
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.430
	10:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
06/28/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.023

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

6/3/2024 to 6/28/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
06/28/2024	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.039
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)