



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/03/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.135	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.138	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.147	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.152	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.157	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.122	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.049	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.017	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.012	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.014	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.074	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.136	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.172	0.000
03/04/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.219	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/04/2025	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.221	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.216	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.221	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.222	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.209	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.204	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.206	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.173	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.124	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.094	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.100	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.169	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.225	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.209	0.000
03/05/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.271	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.276	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/05/2025	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.269	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.262	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.245	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.222	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.187	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.154	0.000
	02:00 PM	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.149	0.000
	03:00 PM	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.122	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.107	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.130	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.192	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.243	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.276	0.000
03/06/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.252	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.271	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.276	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/06/2025	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.280	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.269	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.203	0.000
	12:00 PM	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.146	0.000
	01:00 PM	0.000	0.019	0.000	0.000	0.000	0.000	0.000	0.128	0.000
	02:00 PM	0.000	0.036	0.000	0.001	0.000	0.000	0.000	0.113	0.000
	03:00 PM	0.000	0.015	0.000	0.000	0.000	0.000	0.000	0.112	0.000
	04:00 PM	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.118	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.151	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.206	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.277	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.303	0.000
03/07/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.131	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.061	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.084	0.000
	09:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.077	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/07/2025	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.055	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.050	0.000
	01:00 PM	0.000	0.021	0.000	0.000	0.000	0.000	0.000	0.009	0.000
	02:00 PM	0.000	0.076	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.008	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/10/2025	06:00 AM	0.000	0.118	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.134	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.081	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/10/2025	11:00 AM	0.000	0.074	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.191	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.066	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.063	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/11/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/11/2025	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/12/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/12/2025	01:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/13/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.009	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.007	0.000	0.000	0.058	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.001	0.000	0.000	0.058	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/13/2025	02:00 PM	0.000	0.000	0.000	0.071	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.058	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.018	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/14/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.001	0.000	0.000	0.019	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.147	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.191	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.210	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.150	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.087	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.073	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/14/2025	03:00 PM	0.000	0.000	0.000	0.103	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.028	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/17/2025	06:00 AM	0.000	0.078	0.000	0.001	0.000	0.000	0.000	0.362	0.000
	07:00 AM	0.000	0.083	0.000	0.005	0.000	0.000	0.000	0.041	0.000
	08:00 AM	0.000	0.081	0.000	0.013	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.006	0.106	0.000	0.017	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.092	0.000	0.017	0.000	0.000	0.000	0.002	0.002
	11:00 AM	0.012	0.124	0.000	0.001	0.000	0.000	0.000	0.152	0.000
	12:00 PM	0.006	0.092	0.000	0.027	0.000	0.000	0.000	0.432	0.000
	01:00 PM	0.000	0.073	0.000	0.028	0.000	0.000	0.000	0.804	0.000
	02:00 PM	0.000	0.045	0.000	0.016	0.000	0.000	0.000	0.122	0.000
	03:00 PM	0.000	0.008	0.000	0.001	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/17/2025	04:00 PM	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.019	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.039	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.056	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.070	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/18/2025	06:00 AM	0.000	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.036	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.002	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.007	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.005	0.000	0.000	0.039	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.102	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.084	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/18/2025	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/19/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.003	0.000	0.000	0.052	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.001	0.000	0.000	0.086	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/19/2025	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/20/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.030	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.027	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.116	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/20/2025	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/21/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000
	08:00 AM	0.001	0.000	0.000	0.004	0.000	0.000	0.000	0.001	0.000
	09:00 AM	0.001	0.000	0.000	0.002	0.000	0.000	0.000	0.033	0.000
	10:00 AM	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.059	0.000
	11:00 AM	0.000	0.000	0.000	0.060	0.000	0.002	0.000	0.108	0.000
	12:00 PM	0.000	0.000	0.000	0.032	0.000	0.000	0.000	0.185	0.000
	01:00 PM	0.000	0.000	0.000	0.043	0.000	0.000	0.000	0.254	0.000
	02:00 PM	0.000	0.000	0.000	0.041	0.000	0.000	0.000	0.074	0.000
	03:00 PM	0.000	0.000	0.000	0.030	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/21/2025	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/24/2025	06:00 AM	0.037	0.072	0.000	0.064	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.036	0.054	0.000	0.076	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.036	0.053	0.000	0.094	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.053	0.069	0.000	0.093	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.046	0.019	0.000	0.059	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.023	0.001	0.000	0.059	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.002	0.000	0.000	0.094	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.163	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.041	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.016	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/25/2025	06:00 AM	0.025	0.018	0.000	0.060	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.021	0.014	0.000	0.066	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.023	0.020	0.000	0.050	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.028	0.029	0.000	0.035	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.024	0.043	0.000	0.024	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.006	0.046	0.000	0.031	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.027	0.000	0.067	0.000	0.000	0.000	0.000	0.068
	01:00 PM	0.000	0.004	0.000	0.055	0.000	0.000	0.000	0.000	0.299
	02:00 PM	0.002	0.002	0.000	0.017	0.000	0.000	0.000	0.000	0.009
	03:00 PM	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.008	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.018	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/26/2025	06:00 AM	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/26/2025	07:00 AM	0.024	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.038	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.033	0.079	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.011	0.169	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.094	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/27/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/27/2025	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.002	0.001	0.000	0.007	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.053	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.021	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/28/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/28/2025	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03/31/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.022
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.040
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.063
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.024

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

3/3/2025 to 3/31/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
03/31/2025	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.080	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	1.166	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.877	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)