



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/01/2025	06:00 AM	0.038	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.037	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.034	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.038	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.026	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/02/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/02/2025	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.066	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/05/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.023
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.022

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/05/2025	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.018
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/06/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.018	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.143	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/06/2025	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.379	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.214	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/07/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/07/2025	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/08/2025	06:00 AM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.010	0.000	0.000
	08:00 AM	0.011	0.000	0.000	0.000	0.000	0.000	0.014	0.000	0.000
	09:00 AM	0.032	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000
	10:00 AM	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/08/2025	11:00 AM	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/09/2025	06:00 AM	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.007	0.000	0.000	0.000	0.000	0.001	0.000	0.000
	08:00 AM	0.000	0.007	0.000	0.000	0.000	0.000	0.001	0.000	0.000
	09:00 AM	0.000	0.016	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.039	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.069	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/09/2025	12:00 PM	0.000	0.084	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.088	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.071	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.058	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.035	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/12/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.023
	07:00 AM	0.000	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.009
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.020
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.027
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.019

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/12/2025	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.035
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.034
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.049
05/13/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/13/2025	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/14/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.056	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.063	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.027	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.036	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.030	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.010	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/14/2025	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/15/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/15/2025	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/16/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/16/2025	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/19/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.001	0.000	0.000	0.008	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.002	0.000	0.000	0.008	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.008	0.000	0.000	0.007	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.044
	11:00 AM	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.124
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.052
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.011
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/19/2025	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000
05/20/2025	06:00 AM	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.004	0.000
	09:00 AM	0.001	0.000	0.003	0.000	0.000	0.000	0.000	0.007	0.000
	10:00 AM	0.000	0.000	0.001	0.000	0.001	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.006	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/20/2025	07:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.004	0.000	0.001	0.000	0.000	0.000	0.000
05/21/2025	06:00 AM	0.000	0.000	0.018	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.022	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.022	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.021	0.000	0.004	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/21/2025	08:00 PM	0.000	0.000	0.028	0.000	0.000	0.000	0.000	0.000	0.000
05/22/2025	06:00 AM	0.000	0.000	0.081	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.115	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.132	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.032	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.070	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/23/2025	06:00 AM	0.000	0.000	0.170	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.177	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/27/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/27/2025	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/28/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/28/2025	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.035	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.058	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/29/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/29/2025	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05/30/2025	06:00 AM	0.000	0.000	0.000	0.000	0.029	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.037	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.031	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

5/1/2025 to 5/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
05/30/2025	10:00 AM	0.000	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)