



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/03/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/04/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/04/2024	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/05/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/05/2024	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.004	0.000	0.001	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.035	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.038	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.017	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/06/2024	06:00 AM	0.114	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.088	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.055	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/06/2024	09:00 AM	0.100	0.000	0.000	0.043	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.302	0.000	0.000	0.043	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.029	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.036	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/10/2024	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/11/2024	06:00 AM	0.000	0.081	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/11/2024	07:00 AM	0.000	0.087	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.087	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.102	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.002	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/12/2024	06:00 AM	0.000	0.033	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.037	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/12/2024	08:00 AM	0.000	0.031	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.004	0.000	0.200	0.000	0.002	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.454	0.000	0.001	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.421	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.287	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.069	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.052	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/13/2024	06:00 AM	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.008	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.001	0.000	0.001	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/13/2024	09:00 AM	0.001	0.000	0.000	0.016	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.070	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/16/2024	06:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.022	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.001	0.000	0.000	0.131	0.000	0.001	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv
Ambient Level
(Perimeter)

20
ppmv
Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv
Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv
Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/16/2024	10:00 AM	0.000	0.000	0.000	0.130	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.186	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.119	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.167	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.166	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.138	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.225	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
09/17/2024	06:00 AM	0.000	0.000	0.000	0.168	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.181	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.060	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.086	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/17/2024	11:00 AM	0.000	0.000	0.000	0.072	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/18/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.001	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/18/2024	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/19/2024	06:00 AM	0.000	0.000	0.000	0.115	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.035	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.093	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.008	0.000	0.000	0.067	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/19/2024	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/20/2024	06:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.020	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.042	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.029	0.000	0.001	0.000	0.000	0.000
	11:00 AM	0.002	0.000	0.000	0.001	0.000	0.013	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/20/2024	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000
09/23/2024	06:00 AM	0.003	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.166	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.027	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/23/2024	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/24/2024	06:00 AM	0.002	0.000	0.059	0.015	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.001	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.002	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/24/2024	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/25/2024	06:00 AM	0.010	0.000	0.000	0.126	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.011	0.000	0.000	0.105	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.008	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.033	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.146	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.176	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.176	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.144	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.099	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/25/2024	05:00 PM	0.000	0.000	0.000	0.028	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/26/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/26/2024	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/27/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/27/2024	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09/30/2024	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.016
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.019
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/3/2024 to 9/30/2024

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/30/2024	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

- * Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)
- * It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.
- * Photoionization detector (PID) used to measure total VOCs.
- * Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)