



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/02/2025	06:00 AM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.016	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/03/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/04/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/05/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/08/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/09/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.055	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.058	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/10/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.045	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.030	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.036	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.027	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.013	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/11/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/12/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.050	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.056	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.062	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.056	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/15/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/16/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/17/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/18/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/19/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/22/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.008	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.011	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.013	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.001	0.000	0.011	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.010	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/23/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.034	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.031	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.032	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.036	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/24/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.010	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.012	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/25/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.036	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/26/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/29/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)



Red Hill Air Quality Monitor Readings

Parts Per Million by Volume (ppmv)

9/2/2025 to 9/30/2025

Date	Time	RH-AQM-1 ppmv	RH-AQM-2 ppmv	RH-AQM-3 ppmv	RH-AQM-4 ppmv	RH-AQM-5 ppmv	RH-AQM-6 ppmv	RH-AQM-7 ppmv	RH-AQM-8 ppmv	RH-AQM-9 ppmv
09/30/2025	06:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	09:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	10:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	11:00 AM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	12:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	01:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	02:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	03:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	04:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	05:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	06:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	07:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
	08:00 PM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

* Data during ventilation operational hours (excludes weekends/federal holidays and/or breaks in venting operations)

* It should be noted that there are currently no regulatory VOC levels established for outdoor air quality.

* Photoionization detector (PID) used to measure total VOCs.

* Instrument resolution and range is 0.1 parts per million (ppm) to 15,000 ppm.

Volatile Organic
Compounds (VOC)
Levels Legend

0 - 2
ppmv Ambient Level
(Perimeter)

20
ppmv Cease Ventilation
Operations
(1 Hr total weight average)

38
ppmv Public Notification
Level 1 (8 hr exposure)
(Perimeter)

144
ppmv Level 2
(Perimeter)